
From: Irlam, Lawrence <Lawrence.Irlam@energyaustralia.com.au>
Sent: Monday, 10 August 2020 7:37 PM
To: ENet:Consultation <Consultation.ENet@electranet.com.au>
Subject: FW: Project EnergyConnect Stakeholder update - EA heat rates

CAUTION: This email originated from outside of ElectraNet. Do not click links or open attachments unless you recognise the sender and know the content is safe.

Good evening

With respect to heat rates on our power stations, we only had the following recommended changes / instances of material divergence:

- Hallett – Our Hallett numbers are 15.4, higher than the AEMO of 14.88. Note the new Hallett GT13 has a heat rate of 9.5 and warrants separate treatment
- Jeeralang – our most recent estimate is 14.19, which is lower than the AEMO numbers.

Apologies for the delayed response

Cheers
Lawrence

Lawrence Irlam
Industry Regulation Lead

e lawrence.irlam@energyaustralia.com.au t + 61 3 8628 1655



EnergyAustralia

Level 33, 385 Bourke Street, Melbourne, Victoria, 3000

energyaustralia.com.au



Our goal is to be carbon neutral by 2050.